KUSAM-MECO®

An ISO 9001:2015 Company

KM 4002 AC/DC True RMS

Operating Manual



1000A True RMS Digital Clamp Meter

10/07/2021

Preface

Thank you for purchasing the new clamp meter. In order to use this product safely and correctly, please read this manual thoroughly, especially the *Safety* Instructions part.

After reading this manual, it is recommended to keep the manual at an easily accessible place, preferably close to the device, for future reference.

Table of Contents

I. Overview ---------- 3
II. Accessories ---------- 3
III. Safety Instructions ---------- 4
IV. Electrical Symbols ---------- 5
V. External Structure ---------- 6
VI. LCD Display ---------- 7
VII. Function SwitchDial and Function Buttons ---------- 8
VIII. Specifications ---------- 10
IX. Operating Instructions ---------- 19
X. Maintenance ---------- 35

I. Overview

The KM 4002(AC/DC) is a 6000-count handheld True RMS clamp meter with auto range. This full scale overload protection meter contains the following features:

- AC/DC voltage, AC current, resistance, diode, continuity, capacitance, frequency, duty ratio, data hold, MAX/MIN, relative
- DC current
- Temperature
- LPF (low pass filter) and LoZ (low impedance) voltage
- Inrush current measurement
- Analog bar display
- Flashlight, NCV, low battery indication, and auto power off

The KM 4002(AC/DC) can also be equipped with a flexible current probe to extend the AC current measurement range to 3000A (optional accessory).

⚠ **Warning:**
Before using the meter, please read the Safety Instructions carefully.

II. Accessories

Open the package box and take out the meter. Please double check whether the following items are missing or damaged.

a) User manual ---------- 1 pc
b) Test leads ---------- 1 pair
c) K-type thermocouple ---------- 1 pc
d) Cloth bag ---------- 1 pc
e) 1.5V AAA batteries ---------- 3 pcs
f) Flexible current probe ---------- optional

If any of the above is missing or damaged, please contact your supplier immediately.

KUSAM-MECO®
An ISO 9001:2015 Company

III. Safety Instructions

The meter is designed and manufactured according to IEC61010-1, IEC61010-2-032 and IEC61010-2-033 safety standards, and conforms to CAT III 1000V, CAT IV 600V, double insulation, and pollution degree 2.

⚠ **Note:** Before each use, verify meter operation by measuring a known voltage. If the meter is used in a manner not specified by the manufacturer, the protection provided by the equipment may not be guaranteed.

1. Before use, please check if there is any item which is damaged or behaving abnormally. If any abnormal item (such as bare test lead, damaged meter casing, broken LCD, etc.) is found, or if the meter is considered to be malfunctioning, please do not continue to use the meter.
2. Do not use the meter if the rear cover or the battery cover is not completely covered up, it may pose a shock hazard!
3. When using the meter, keep fingers behind the finger guards of the test leads, and do not touch exposed wires, connectors, unused inputs, or circuits being measured to prevent electric shock.
4. The function dial should be placed in the correct position before measurement.
5. Do not apply voltage over 1000V between any meter terminal and earth ground to prevent electric shock or damage to the meter.
6. Use caution when working with voltage above AC 30Vrms, 42Vpeak or DC 60V. Such voltages pose a shock hazard.
7. Never input voltage or current which exceeds the specified limit. If the range of the measured value is unknown, the maximum range should be selected.
8. Before measuring the resistance, diode and continuity, switch off the power supply of the circuit, and fully discharge all capacitors to avoid inaccurate measurement.
9. When the "▭" symbol appears on the LCD, please replace the batteries in time to ensure measurement accuracy. If the meter is not in use for a long time, please remove the batteries.
10. Do not change the internal circuit of the meter to avoid damage to the meter and user!
11. Do not use or store the meter in high temperature, high humidity, flammable, explosive or strong magnetic field environments.
12. Clean the meter casing with a soft cloth and mild detergent. Do not use abrasives or solvents!


IV. Electrical Symbols

Symbol	Description
⧈	Equipment protected throughout by DOUBLE INSULATION or REINFORCED INSULATION
⏚	Earth (ground)
⚠	Warning or Caution
~	Alternating current
⎓	Direct current
•))	Continuity buzzer
▶|	Diode
⊣⊢	Capacitance
≂	Alternating current or direct current
⚠	Caution, possibility of electric shock
⧈	Application around and removal from UNINSULATED HAZARDOUS LIVE conductors is permitted.
CE	Complies with European Union standards
ETL Intertek 4007882	Conforms to UL STD 61010-1, 61010-2-032, 61010-2-033, Certified to CSA STD C22.2 No. 61010-1, 61010-2-032, 61010-2-033.
CAT III	It is applicable to testing and measuring circuits connected to the distribution part of the building's low-voltage MAINS installation.
CAT IV	It is applicable to testing and measuring circuits connected at the source of the building's low-voltage MAINS installation.

KUSAM-MECO®
An ISO 9001:2015 Company


V. External Structure (Picture 1)

1. Clamp jaws
2. Hand guard
3. LED indicator light
4. Jaw opening trigger
5. Function dial
6. LCD display
7. Function buttons
8. NCV sensor
9. FLIGHT button
10. Flashlight LED light
11. Battery cover
12. Input jacks



Picture 1

VI. LCD Display



1.	Low battery	12.	Continuity test
2.	Inrush current measurement	13.	NCV
3.	High voltage	14.	Low impedance measurement
4.	Auto power off	15.	Unit
5.	Relative value	16.	Range indicator for the flexible current probe
6.	AC signal	17.	Analog bar
7.	DC signal	18.	Auto range
8.	Flexible current probe	19.	Max measurement
9.	Data hold	20.	Min measurement
10.	DC current zero	21.	Temperature measurement
11.	Diode test	22.	Low pass filter measurement

Remark 1: Regarding the range of the flexible current probe, the analog bar is defined as follows.

Range	Description
30.00A	One segment represents 1.00A
300.0A	One segment represents 10.0A
3000A	One segment represents 100A

VII. Function Dial and Function Buttons

1.Function Dial

Dial Position	Description
A⎓ A~ A≅	AC/DC current measurement
V~ V⎓ V≅	AC/DC voltage measurement
Ω	Resistance measurement
⯈|	Diode test
•))	Continuity test
⊣⊢	Capacitance measurement
Hz	Frequency measurement
%	Duty ratio measurement
℃/℉	Temperature measurement
NCV	Non-contact AC voltage sensing
	Measurement by flexible current probe
LPF V	Low pass filter measurement for AC voltage
LoZ V	Low impedance measurement for AC voltage
OFF	Power off

2. Function Buttons

Note:
Short press: pressing a button for less than 2s.
Long press: pressing a button for more than 2s.

1) SELECT Button
Short press: switch between functions for each dial position.
Long press: enable/disable the LPF function in voltage mode.

2) HOLD/¤ Button
Short press: turn on/off data hold.
Long press: turn on/off backlight.

3) MAX/MIN Button
Short press: enter maximum/minimum measurement mode (no auto power off function in this mode).
Long press: exit maximum/minimum measurement mode. Only valid for ACV, LoZ V~, DCV, ACA, DCA, Ω, CAP, °C/°F, and measurement by flexible current probe.

4) REL or REL ZERO Button
Short press: enter/exit the relative value measurement mode.
LCD would display "Δ".
Displayed value = measured value - reference value
Only valid for ACV, DCV, ACA, Ω and CAP (in the case of CAP, the REL button is used to clear the base).
In the DCA measurement mode, short press the REL ZERO button to enter/exit the zero mode.

5) RANGE Button
Short press: enter the manual range mode and change the range.
Long press: Long press or turn function dial to exit manual range mode.
Only valid for ACV, LPF ACV, LoZ V~, DCV, ACA, DCA, CAP and Ω.

KUSAM-MECO®
An ISO 9001:2015 Company

6) Hz/INRUSH Button
Short press: enter/exit the frequency measurement mode.
Only valid for ACV, LPF ACV, LoZ V~, ACA and measurement by flexible current probe.
Long press: user has the option to select proper range with RANGE button first, or simply long press this button to enter the inrush current measurement mode (measurement time~100ms). Long press this button again to exit the inrush current measurement mode.
Inrush current can also be measured with flexible current probe

7) FLIGHT Button
Short press: turn on/off the flashlight.

VIII. Specifications

1. General Specifications

Max display: ---------- 6000 counts
Polarity display: ---------- Auto
Overload display: ---------- "OL" or "-OL"
Low battery indication: ---------- " " is displayed.
Sampling rate: ---------- 3 times/s
Sensor type: ---------- Hall effect sensor

Test position error: ---------- If the source under test is not placed at the center of the clamp jaws when measuring current, ±1.0% additional error in reading may be produced.
Jaw opening: ---------- 42mm
Battery: ---------- 3×1.5V AAA
Auto power off: ---------- 15 minutes (can be disabled)
Dimensions: ---------- Approx. 272mm×81mm×43.5mm
Weight (including batteries): ----- Approx. 447g

2. Environmental Specifications

Operating altitude:---------- upto 2000m
Safety standards:---------- IEC61010-1, IEC61010-2-032,
IEC61010-2-033;
CAT III 1000V, CAT IV 600V
Pollution degree:---------- 2
Operating temperature and humidity:----- 0°C~30°C (≤80%RH), 30°C~40°C
(≤75%RH), 40°C~50°C (≤45%RH)
Storage temperature and humidity:------ -10°C~60°C (≤80%RH)
Electromagnetic compatibility:---------- When RF=1V/m:
overall accuracy = specified accuracy
+ 5% of range
When RF>1V/m: not specified

3. Electrical specifications

Accuracy:---------- ± (a% of reading + b digits),
1 year calibration cycle
Ambient temperature:---------- 23°C±5°C
Ambient humidity:---------- ≤80%RH

⚠ **Note:**
To ensure measurement accuracy, the operating temperature should be within 18°C~28°C and the fluctuation range should be within ±1°C. When the temperature is <18°C or >28°C, add temperature coefficient error 0.1 x (specified accuracy)/°C.

KUSAM-MECO®
An ISO 9001:2015 Company

1) AC Current ($\tilde{A}$)

Range	Resolution	Accuracy	Overload Protection
60.00A	0.01A	± (2.0%+9)	1000V DC/AC
600.0A	0.1A	± (2.0%+5)	
1000A	1A		

- Display: True RMS
- Accuracy guarantee: 5%~100% of range. Open circuit allows least significant digit ≤ 0.
- Frequency response: 40Hz~400Hz
- The AC crest factor will reach 3.0 at 3000 counts while only reach ≤1.5 at
- 6000 counts. The additional error should be added according to the crest factor of a non-sinusoidal wave are:

  a) Add 4% when crest factor is 1~2
  b) Add 5% when crest factor is 2~2.5
  c) Add 7% when crest factor is 2.5~3
- For current frequency monitoring, the resolution is 0.1Hz and accuracy is ± (0.1%+3). The input amplitude should be ≥10% of range.

2) Inrush Current ($\widetilde{A}$)

Function	Range	Resolution	Accuracy	Overload Protection
Inrush current (ACA)	60.00A	0.01A	± (10%+10)	1000A
	600.0A	0.1A		
	1000A	1A		
Inrush current (flexible current probe)	30.00A	0.01A	± (10%+10)	3000A
	300.0A	0.1A		
	3000A	1A		

- measurement time ~ 100ms.

3) DC Current ($\overline{\overline{A}}$)

Range	Resolution	Accuracy	Overload Protection
60.00A	0.01A	± (2.0%+5)	1000A
600.0A	0.1A		
1000A	1A		

- Accuracy guarantee: 5%~100% of range
- Press the REL ZERO button to remove any DC offset that could affect the accuracy of reading.

KUSAM-MECO®
An ISO 9001:2015 Company

4)AC Voltage ($\widetilde{V}$)

Range	Resolution	Accuracy	Overload Protection
6.000V	0.001V	± (1.2%+3)	1000V
60.00V	0.01V		
600.0V	0.1V	± (1.0%+8)	
1000V	1V		

- Display: True RMS
- Accuracy guarantee: 5%~100% of range. Short circuit allows least significant digit ≤5.
- Input impedance: ≥10MΩ
- Frequency response: 40Hz~400Hz
- The AC crest factor will reach 3.0 at 3000 counts while only reach ≤1.5 at 6000 counts. The additional error should be added according to the crest factor of a non-sinusoidal wave are:
  a) Add 4% when crest factor is 1~2
  b) Add 5% when crest factor is 2~2.5
  c) Add 7% when crest factor is 2.5~3
- For voltage frequency monitoring, the resolution is 0.1Hz and accuracy is ± (0.1%+3). The input amplitude should be ≥10% of range.

5)LPF ACV

Range	Resolution	Accuracy	Overload Protection
600.0V	0.1V	± (2.0%+5)	1000V
1000V	1V		

- Display: True RMS
- Accuracy guarantee: 5%~100% of range. Short circuit allows least significant digit ≤5.
- Input impedance: ≥10MΩ
- Frequency response: 40Hz~200Hz
- The AC crest factor will reach 3.0 at 3000 counts while only reach ≤1.5 at 6000 counts. The additional error should be added according to the crest factor of a non-sinusoidal wave as follows:

a) Add 4% when crest factor is 1~2
b) Add 5% when crest factor is 2~2.5
c) Add 7% when crest factor is 2.5~3

- The -3dB frequency of LPF is about 2.5kHz
  Only manual range for LPF ACV. Use the RANGE button to change the range.
- For voltage frequency monitoring, the resolution is 0.1Hz and accuracy is ± (0.1%+3). The input amplitude should be ⩾10% of range.

6)LoZ V~

Range	Resolution	Accuracy	Overload Protection
600.0V	0.1V	± (2.0%+5)	1000V
1000V	1V		

- Display: True RMS
- Accuracy guarantee: 5%~100% of range. Short circuit allows least significant digit ⩽5.
- Input impedance: About 2kΩ
- Frequency response: 40Hz~400Hz
- The AC crest factor will reach 3.0 at 3000 counts while only reach ⩽1.5 at 6000 counts. The additional error should be added according to the crest factor of a non-sinusoidal wave as follows:
  a) Add 4% when crest factor is 1~2
  b) Add 5% when crest factor is 2~2.5
  c) Add 7% when crest factor is 2.5~3
- **When the measured voltage is above 220V, the continuous measurement time cannot exceed 30s and the rest interval should be more than 30s.**
- For voltage frequency monitoring, the resolution is 0.1Hz and accuracy is ± (0.1%+3). The input amplitude should be ⩾10% of range.

KUSAM-MECO®
An ISO 9001:2015 Company

7) DC voltage ($\overline{\overline{V}}$)

Range	Resolution	Accuracy	Overload Protection
600.0mV	0.1mV	± (0.8%+3)	1000V
6.000V	0.001V	± (0.5%+5)	
60.00V	0.01V		
600.0V	0.1V		
1000V	1V		

- Input impedance: ⩾10MΩ
- Accuracy guarantee: 5%~100% of range. Short circuit allows least significant digit ⩽5.

8) Resistance (Ω)

Range	Resolution	Accuracy	Overload Protection
600.0Ω	0.1Ω	± (1.0%+3)	1000V
6.000kΩ	0.001kΩ	± (1.0%+2)	
60.00kΩ	0.01kΩ		
600.0kΩ	0.1kΩ		
6.000MΩ	0.001MΩ	± (2.0%+8)	
60.00MΩ	0.01MΩ		

- Measurement result = displayed value – resistance of shorted test leads
- Open circuit voltage: About 1V
- Accuracy guarantee: 5%~100% of range

9) Continuity (•))

Range	Resolution	Accuracy	Overload Protection
600.0Ω	0.1Ω	Open circuit: Resistance ⩾70Ω, no beep Well-connected circuit: Resistance ⩽30Ω, consecutive beeps	1000V

- Open circuit voltage: About 1V
- Resistance value is between 30Ω and 70Ω, the Buzzer maybe beep

10) Diode (▶|)

Range	Resolution	Accuracy	Overload Protection
6.000V	0.001V	Open circuit voltage: About 3V Measurable PN junction: Forward voltage drop ⩽3V For silicon PN junction, the normal value is generally about 0.5~0.8V.	1000V

11) Capacitance (⊣⊢)

Range	Resolution	Accuracy	Overload Protection
60.00nF	0.01nF	± (4.0%+25)	1000V
600.0nF	0.1nF	± (4.0%+5)	
6.000μF	0.001μF		
60.00μF	0.01μF		
600.0μF	0.1μF		
6.000mF	0.001mF	± (10.0%+9)	
60.00mF	0.01mF		

KUSAM-MECO®
An ISO 9001:2015 Company

- Measurement result = displayed value – capacitance of open-circuit test leads
- For capacitance ⩽1μF, it is recommended to use “REL” measurement mode.
- Accuracy guarantee: 5%~100% of range

12) Temperature (°C/°F)

Range	Resolution	Accuracy	Overload Protection
-40℃~300℃	0.1℃	±(1.0%+20)	1000V
300℃~1000℃	1℃	±(1.0%+2)	
-40℉ ~572℉	0.2℉	±(1.0%+40)	
573℉~1832℉	1℉	±(1.0%+4)	

- Only K-type thermocouple is applicable.
- If the ambient temperature in the meter differs by ±5 °C, the accuracy can only be guaranteed after 1 hour of cool down.
- Open circuit display: “OL”

13) Frequency/Duty Ratio (Hz%)

Range	Resolution	Accuracy	Overload Protection
10Hz~1 MHZ	0.01Hz~1K Hz	±(0.1%+3)	1000V
10.0%~90.0%	0.1%	±(2.6%+7)	


- Frequency input amplitude:
  10Hz~100kHz: 250mVrms ⩽ input amplitude ⩽ 20Vrms
  100kHz~1MHz: 600mVrms ⩽ input amplitude ⩽ 20Vrms
- Duty ratio:
  10%~90%: for square waves of 10Hz~1kHz
  30%~70%: for square waves of 1kHz~10kHz
  2Vpp⩽ input amplitude ⩽20Vpp

14) Non-contact AC voltage sensing (NCV)

Range	Accuracy	Overload Protection
NCV	Bring the NCV sensor (upper tip) close to a wire to start sensing. When no voltage is sensed, the LCD displays "EF". As the intensity of the detected voltage increases, more segments "—" will be displayed, and higher frequently occurs for buzzer and flashing LED.	1000V

IX. Operating Instructions

1.Related Measurement of AC Current (Picture 5)



Picture 5

KUSAM-MECO®
An ISO 9001:2015 Company

AC Current Measurement

1) Turn the function dial to **A~**, A~ , or A≅ position.
2) Press the trigger to open clamp jaws and fully enclose one conductor (only one conductor can be measured at a time). For optimum results, center the conductor in the jaws.


Current Frequency Measurement

1) When the function dial is in the AC current position, short press the Hz or Hz/ INRUSH button to enter the frequency measurement mode.
2) Short press the Hz or Hz/INRUSH button again to exit the frequency measurement mode.

Inrush Current Measurement (for AC current)

1) User has the option to select proper range with RANGE button first, or simply long press the Hz/INRUSH button to enter the inrush current measurement mode.
2) Start the device under test and measure the instantaneous inrush current of the device.
4) Long press the Hz/INRUSH button again to exit the inrush current measurement mode.

Inrush current is the highest AC current (true RMS) within 100ms of start time, as shown below.



⚠ **Note:**

- The current measurement should be taken within 0°C~40°C. Do not suddenly release the trigger, as the impact may change the reading for a short time.
- To ensure measurement accuracy, center the conductor within the jaws. Otherwise, ±1.0% additional error in reading may be produced.
- When testing high current, the clamp will vibrate slightly, which is a normal phenomenon.


2. DC Current Measurement (Picture 5)

1) Turn the function dial to the A⎓ or A≃ position.
2) Short press the SELECT button to switch to DC current measurement. If the display on the LCD is not zero, short press the REL ZERO button to enable zero clearing.
3) Press the trigger to open the clamp jaws, and fully enclose one conductor (only one conductor can be measured at a time). For optimum results, center the conductor within the jaws.

⚠ **Note:**

- The current measurement must be taken within 0°C~40°C. For DC current measurement, if the reading is positive, the direction of current is from top to bottom (from panel to cover). Do not suddenly release the trigger, as the impact will change the reading for a short time.
- To ensure measurement accuracy, center the conductor in within jaws. Otherwise, ±1.0% additional error in reading will be produced.
- After DC current (especially large current) measurement, the open circuit base may be too large. Please do an AC current test to eliminate the residual magnetic signal generated by the jaws.

3. Measurement by Flexible Current Probe (Picture 6)



Picture 6

AC Current Measurement

1) Turn the function dial to the A~ or A≃ position.
2) Insert the flexible current probe into the VΩ Hz%°C°F jacks and **COM** jacks.
3) The meter will automatically switch to the flexible current probe with the extended current range, displayed on LCD.


Current Frequency Measurement

1) After connecting the flexible current probe, short press the Hz/INRUSH button to enter the frequency measurement mode.
2) Short press the Hz/INRUSH button again to exit frequency measurement mode.


Inrush Current Measurement

1) After connecting the flexible current probe, short press the RANGE button to select the proper range.
2) Long press the Hz/INRUSH button to enter the inrush current measurement mode.
3) Start the appliance under test and measure the instantaneous inrush current of the appliance.
4) Long press the Hz/INRUSH button again to exit the inrush current measurement mode.

Inrush current is the highest AC current (true RMS) within 100ms of start time, as shown below.



4. Related Measurement of AC Voltage and LPF ACV (Picture 7)



Picture 7

AC Voltage Measurement


1) Insert the red test lead into $V\Omega$ Hz % ⊣(⊷ ⊷ ·)) , Ω ⊣(⊷ ⊷ ·)) , V Hz % , or $V\Omega$ ⊣(⊷ ⊷ ·)) Hz % °C °F jack, and black test lead into the COM jack.
2) Turn the function dial to V~ or V≅ position.
3) Short press the SELECT button to switch to AC voltage measurement if required, and connect the test leads with the measured load or power supply in parallel.

Voltage Frequency Measurement

1) When the function dial is in the AC voltage, short press Hz or Hz/INRUSH button to enter the frequency measurement mode.
2) Short press Hz or Hz/INRUSH button again to exit frequency measurement mode.

LPF ACV Measurement

1) When the function dial is in the AC voltage position, long press SELECT button to enable LPF ACV function. LPF can measure combined sine wave signals produced by inverters and variable frequency drives, as shown below.



2) After enabling the LPF ACV function, short press the Hz/INRUSH button to enter the frequency measurement mode.
3) Short press the Hz/INRUSH button again to exit the frequency measurement mode.

⚠ **Note:**

- Do not input voltage above 1000V. Although it is possible to measure higher voltage, it may damage the meter.
- Be cautious to avoid electric shock when measuring high voltage.
- After completing the measurement, disconnect the test leads from the circuit under test.
- When the measured voltage is above 30V, the LCD will display the high voltage alarm prompt " ϟ ".

KUSAM-MECO®
An ISO 9001:2015 Company

5. DC Voltage Measurement (Picture 7)

1) Insert the red test lead into the VΩHz%, Ω, VHz% or VΩ Hz%°C°F jack, and black test lead into the COM jack.
2) Turn the function dial to the V⎓ or V≅ position.
3) Short press the SELECT button to switch to DC voltage measurement if required, and connect the test leads with the measured load or power supply in parallel.
4) Read the voltage value on the display.

⚠ **Note:**

- Do not input voltage above 1000V. Although it is possible to measure higher voltage, it may damage the meter.
- When measuring at 600mV range, use "REL" measurement mode to get accurate readings. Short-circuit the test leads, and then short press the REL or REL ZERO button. Read the measured voltage after the voltage of the short-circuited test leads is automatically subtracted.
- Be cautious to avoid electric shock when measuring high voltage.
- After completing the measurement, disconnect the test leads from the circuit under test.
- When the measured voltage is above 30V, the LCD will display the high voltage alarm prompt " ϟ ".


6. LoZ Measurement (Picture 8)

LoZ ACV Measurement

1) Insert the red test lead into Ω VHz% or VΩ Hz%°C°F jack, and black test lead into the **COM** jack.
2) Turn the function dial to the **LoZ V~** position, and connect the test leads with the measured load or power supply in parallel.

LoZ ACV Frequency Measurement

1) When the function dial is in the LoZ ACV position, short press the Hz/INRUSH button to enter the frequency measurement mode.
2) Short press the Hz/INRUSH button again to exit the frequency measurement mode.




Picture 8

⚠ **Note:**

- Do not input voltage above 1000V. Although it is possible to measure higher voltage, it may damage the meter.
- Be cautious to avoid electric shock when measuring high voltage.
- Test known voltage before use to verify whether the product functions correctly.
- After using the LoZ function, let the meter rest for 3 minutes before next use.
- LoZ voltage measurement eliminates ghost voltage for more accurate measurement.
- When the measured voltage is above 30V, the LCD will display the high voltage alarm prompt " ϟ ".

7. Resistance Measurement (Picture 9)



Picture 9

1) Insert the red test lead into the VΩHz%, ΩVHz% or VΩHz%°CF jack, and black test lead into the COM jack.
2) Turn the function dial to the Ω or Ω position, short press the SELECT button to switch to resistance measurement if required, and connect the test leads with both ends of the measured resistance in parallel.

⚠ **Note:**

- If the measured resistor is open or the resistance exceeds the maximum range, the LCD will display "OL".
- Before measuring the resistance online, switch off the power supply of the circuit, and fully discharge all capacitors to ensure accurate measurement.
- When measuring low resistance, the test leads will produce 0.1Ω~0.2Ω measurement error. Use "REL" measurement mode to get accurate readings. Short-circuit the test leads, and then short press the REL or REL ZERO button. After the meter automatically subtracts the resistance of the short-circuited test leads, the low-resistance measurement can be performed.
- If the resistance is not less than 0.5Ω when the test leads are short-circuited, please check the test leads for abnormalities.

- When measuring resistance above 1MΩ, it is normal to take a few seconds to stablize reading.
- Use caution when working with voltage above AC 30Vrms, 42Vpeak or DC 60V. Those voltages may pose shock hazard.
- After completing the measurement, disconnect the test leads from the circuit under test.

8.Continuity Test (Picture 9)

1) Insert the red test lead into the VΩHz%, Ω, or VΩ jack, and black test lead into the COM jack.
2) Turn the function dial to Ω or Ω position, short press SELECT button to switch to continuity test, and connect the test leads with both ends of measured load in parallel.
3) When the measured resistance ⩽30Ω: The circuit is in good conduction status; the buzzer beeps continuously. When measured resistance ⩾70Ω: there will be no buzzer sound.

⚠ **Note:**

- Before measuring the continuity online, switch off the power supply of the circuit, and fully discharge all capacitors.
- Use caution when working with voltage above AC 30Vrms, 42Vpeak or DC 60V. Those voltages may pose shock hazard.
- After completing the measurement, disconnect the test leads from the circuit under test.

9.Diode Test (Picture 9)


1) Insert the red test lead into the VΩHz%, Ω, or VΩ jack, and black test lead into the COM jack. The polarity of the red test lead is “+” and that of the black test lead is “-”.
2) Turn the function dial to the Ω or Ω position, and short press the SELECT button to switch to diode test.

3) Connect the red probe with the diode anode, and black with the diode cathode.
4) Read the approximate forward voltage of the diode on the display. For silicon PN junction, the normal value is generally about 500~800 mV.

⚠ **Note:**

- If the diode is open or its polarity is reversed, the LCD will display “OL”.
- Before measuring the diode online, switch off the power supply of the circuit, and fully discharge all capacitors.
- Use caution when working with voltage above AC 30Vrms, 42Vpeak or DC 60V. Such voltage poses a shock hazard.
- After completing the measurement, disconnect the test leads from the circuit under test.

10. Capacitance Measurement (Picture 10)




Picture 10

1) Insert the red test lead into the V Ω Hz % , Ω V Hz % or V Ω Hz % °C °F jack, and black into the **COM** jack.
2) Turn the function dial to the Ω position, short press the SELECT button to switch to capacitance measurement, and connect the test leads with both ends of the measured capacitance in parallel.

⚠ **Note:**

- If the measured capacitor is short-circuited or the capacitance exceeds the maximum range, the LCD will display “OL”.
- The analog bar pointer is disabled in capacitance measurement mode. When measuring capacitance >600μF, it may take some time to steady the readings.
- Before measuring, fully discharge all capacitors (especially high-voltage capacitors) to avoid damage to the meter and user.
- After completing the measurement, disconnect the test leads from the circuit under test.

11.Frequency/Duty Ratio Measurement (Picture 11)



Picture 11


KUSAM-MECO®
An ISO 9001:2015 Company

1) Insert the red test lead into the V Ω Hz % , V Ω Hz % or V Ω Hz % °C °F jack, and black into the **COM** jack.
2) Turn the function dial to the Hz% position, and connect the test leads with both ends of the measured signal source in parallel.
3) Short press the SELECT button to switch to frequency/duty ratio measurement.

⚠ **Note:**

- Do not input voltage higher than 30Vrms to avoid personal injury.
- After completing the measurement, disconnect the test leads from the circuit under test.

12. Temperature Measurement (Picture 12)




Picture 12

1) Turn the function dial to the °C°F position, and the LCD will display “OL”. Ambient temperature will be displayed if users short-circuit the test leads.
2) Insert the K-type thermocouple into the meter as shown.
3) Use the temperature sensor to measure object surface, and read the Celsius temperature value on the LCD after a few seconds.
4) Short press the SELECT button to switch to Fahrenheit temperature measurement.

⚠ **Note:**

- The ambient temperature of the meter should be in the range of 18-28°C, otherwise it may cause measurement error, especially in low temperature environments.
- Use caution when working with voltage above AC 30Vrms, 42Vpeak or DC 60V. Such voltage poses a shock hazard.
- After completing the measurement, remove the thermocouple.

13. Non-contact AC voltage sensing (NCV) (Picture 13)



Picture 13

KUSAM-MECO®
An ISO 9001:2015 Company

1) Turn the function dial to the NCV position, and bring the NCV sensor close to the wire under test.
2) If there is AC voltage or electromagnetic field in the space, the LCD will display the sensing intensity from weak to strong by “—”. At the same time, the buzzer will beep intermittently and the LED indicator light will be on. When no voltage is sensed, the LCD displays “EF”.


14. Auto Power Off

During measurement, if there is no operation of the function dial or any button for 15 minutes, the meter will automatically shut down to save power. Users can wake it up by pressing any button (except FLIGHT button). To disable the auto-off function, press and hold the SELECT button in the off state and turn on the meter.

15. Use of Test Leads


1) Testing in CAT III/CAT IV measurement locations:

Ensure the test lead shields are pressed firmly in place. Failure to use the CATIII/CATIV shields increases arc-flash risk.



2) Testing in CAT II measurement locations:

CAT III/CAT IV shields may be removed for CAT II locations. This will allow testing on recessed conductors such as standard wall outlets. Take care not to lose the shields.



X. Maintenance


⚠ Warning: Before opening the rear cover of the meter, remove the test leads to avoid electric shock.

1.General Maintenance

1) The maintenance and service must be implemented by qualified professionals or designated departments.
2) Clean the meter casing with a soft cloth and mild detergent. Do not use abrasives or solvents!

2.Battery Replacement (Picture 14)

1) Turn off the meter and remove the test leads from the input jacks.
2) Unscrew and remove the battery cover.
3) Replace with 3 standard AAA batteries according to the polarity indication.
4) Secure the battery cover and tighten the screw.



Picture 14

3.Test Lead Replacement

If the insulation on the test lead is damaged, replace it.

⚠Warning:
Test leads used for MAINS measurement should meet EN 61010-031 standard, rated CAT III 1000V, 10A or better.

KUSAM-MECO®
An ISO 9001:2015 Company

TEST CERTIFICATE

1000A TRMS DIGITAL CLAMPMETER

This Test Certificate warrantees that the product has been inspected and tested in accordance with the published specifications.

The instrument has been calibrated by using equipment which has already been calibrated to standards traceable to national standards.

MODEL NO. _____

SERIAL NO. _____

DATE: _____

MUMBAI

ISO 9001:2015

QC
KUSAM-MECO
PASS

WARRANTY

Each “KUSAM-MECO” product is warranted to be free from defects in material & workmanship under normal use & service. The warranty period is one year (12 months) and begins from the date of despatch of goods. In case any defect occurs in functioning of the instrument, under proper use, within the warranty period, the same will be rectified by us free of charges, provided the to and fro freight charges are borne by you.

This warranty extends only to the original buyer or end-user customer of a “KUSAM-MECO” authorized dealer.

This warranty does not apply for damaged Ic’s, fuses, burnt PCB's, disposable batteries, carrying case, test leads, or to any product which in “KUSAM-MECO’s” opinion, has been misused, altered, neglected, contaminated or damaged by accident or abnormal conditions of operation or handling.

“KUSAM-MECO” authorized dealer shall extend this warranty on new and unused products to end-user customers only but have no authority to extend a greater or different warranty on behalf of “KUSAM-MECO”.

“KUSAM-MECO’s” warranty obligation is limited, at option, free of charge repair, or replacement of a defective product which is returned to a “KUSAM-MECO” authorized service center within the warranty period.

THIS WARRANTY IS BUYER’S SOLE AND EXCLUSIVE REMEDY & IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE.“KUSAM-MECO” SHALL NOT BE LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OR LOSSES, INCLUDING LOSS OF DATA, ARISING FROM ANY CAUSE WHATSOEVER.

All transaction are subject to Mumbai Jurisdiction.

KUSAM-MECO®
An ISO 9001:2015 Company

KUSAM-MECO®

OFFICE ADDRESS / SERVICE CENTER

Shop no.18, 1st Floor, CIDCO Shopping Complex, Plot # 9, Sector-7,

Rajiv Gandhi Marg, Sanpada, Navi Mumbai - 400705.

INDIA. **Sales Direct :** +91-9867488006, 9867675093

Email : sales@kusam-meco.co.in **Website :** www.kusamelectrical.com